



**TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.**  
**Technical and Test Institute for Construction Prague**

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán / Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body. Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Branch 0300 – Pilsen

# CERTIFICATE

No. 030 – 049972

## on the qualities of a product

**Certified quality:** determination of lead and cadmium given off by glazed tiles according to the following test procedure:

EN ISO 10545-15 Ceramic tiles – Part 15: Determination of lead and cadmium given off by glazed tiles

**Product:** Ceramic tiles dry pressed  
 series: ARCHITECT KD, ARCHITECT KDS, ARCHITECT FT, PEBBLES

**Producer:** Zorka Keramika d.o.o., Hajduk Veljkova 1, 15 000 Šabac, Serbia

**Order:** Z 030140177

**Achieved values:**

Testing of samples	Determined concentration		Desired concentration	
	[mg/l]		[mg/dm <sup>2</sup> ]	
	Pb	Cd	Pb	Cd
serie: ARCHITECT KD	0,055	0,002	0,0025	0,0001
serie: ARCHITECT KDS	0,030	0,000	0,0016	0,0000
serie: ARCHITECT FT	0,015	0,002	0,0008	0,0001
serie: PEBBLES	0,000	0,001	0,0000	0,0000

The tested samples may be used on worktops and wall surface where food preparation takes place and food may be in the direct contact with the glazed tile surface.

The certificate is issued on the basis of the results of the tests stated in report No. 030–046667 from 31 May 2012.


Number of pages of certificate: 1

Certificate validity:

till 30<sup>th</sup> June 2016

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.

Pilsen 1<sup>st</sup> June 2014



Stamp of ZÚS – branch Pilsen

Ing. Alexander Trinner  
Branch Director

**Warning:** Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.

Technical and testing construction institute Prague, state enterprise, branch 0300 - Pilsen, Zahradní 15, 326 00 Pilsen, Czech Republic  
 ☎: 377 243 331, ☎: 377 430 345, Fax: +420 377 430 347, Internat.: +420 377 244 158, ✉ e-mail: atrinner@tzus.cz, www.tzus.cz  
 Banking details: KB Prague 1 Czech Republic, account number: 1501-931/0100 Co. Id. No.: 000 15679 Tax Co. Id. No.: CZ-00015679